

SPECIFICATION

1.Scope: This specification established a description for PVC insulation,Cotton yarn for Filler, Cotton paper for Seperator and TPU jacket cable.			3.Physical and Electrical Performance <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 40%;">Item</th> <th style="width: 20%;"></th> <th style="width: 40%;">Requirement</th> </tr> </thead> <tbody> <tr> <td>Spark Test</td> <td style="text-align: right;">kv</td> <td>3.0 for insulation; 3.0 for jacket</td> </tr> <tr> <td>Conductor resistance</td> <td style="text-align: right;">ohm/km</td> <td>13.3 (at 20°Cmax)</td> </tr> <tr> <td rowspan="2">Temperature rating</td> <td style="text-align: right;">Occasional flexing</td> <td>- 5°C up to +70°C max. conductor temp.</td> </tr> <tr> <td style="text-align: right;">Fixed installation</td> <td>- 40°C up to +80°C max. conductor temp.</td> </tr> <tr> <td>Voltage rating (U₀ / U)</td> <td style="text-align: right;">V</td> <td>300/500</td> </tr> <tr> <td>Test voltage (Core/Core)</td> <td></td> <td>4000V AC</td> </tr> <tr> <td>Flame retardant test</td> <td></td> <td>FT2</td> </tr> <tr> <td>UV resistance</td> <td></td> <td>acc. to EN 50620 resp. VDE 0285-620 acc. to EN ISO 4892-2-2013, method A (change of colour allowed)</td> </tr> <tr> <td>Ozone resistance</td> <td></td> <td>acc. to EN 50396 resp. VDE 0473-396, method B</td> </tr> <tr> <td>Oil Resistant Jacket (UL758&UL1581)</td> <td></td> <td>(7d @ 60°C)</td> </tr> <tr> <td>Cold bend (-40°Cx4h)</td> <td></td> <td>No cracks</td> </tr> <tr> <td>Minimum bending radius</td> <td></td> <td>Occasional flexing: 12.5 x cable diameter Fixed installation: 6 x cable diameter</td> </tr> <tr> <td>General requirements</td> <td></td> <td>These cables are conform to the EU-Directive 2014/35/EU (Low Voltage Directive)</td> </tr> </tbody> </table>			Item		Requirement	Spark Test	kv	3.0 for insulation; 3.0 for jacket	Conductor resistance	ohm/km	13.3 (at 20°Cmax)	Temperature rating	Occasional flexing	- 5°C up to +70°C max. conductor temp.	Fixed installation	- 40°C up to +80°C max. conductor temp.	Voltage rating (U ₀ / U)	V	300/500	Test voltage (Core/Core)		4000V AC	Flame retardant test		FT2	UV resistance		acc. to EN 50620 resp. VDE 0285-620 acc. to EN ISO 4892-2-2013, method A (change of colour allowed)	Ozone resistance		acc. to EN 50396 resp. VDE 0473-396, method B	Oil Resistant Jacket (UL758&UL1581)		(7d @ 60°C)	Cold bend (-40°Cx4h)		No cracks	Minimum bending radius		Occasional flexing: 12.5 x cable diameter Fixed installation: 6 x cable diameter	General requirements		These cables are conform to the EU-Directive 2014/35/EU (Low Voltage Directive)
Item		Requirement																																												
Spark Test	kv	3.0 for insulation; 3.0 for jacket																																												
Conductor resistance	ohm/km	13.3 (at 20°Cmax)																																												
Temperature rating	Occasional flexing	- 5°C up to +70°C max. conductor temp.																																												
	Fixed installation	- 40°C up to +80°C max. conductor temp.																																												
Voltage rating (U ₀ / U)	V	300/500																																												
Test voltage (Core/Core)		4000V AC																																												
Flame retardant test		FT2																																												
UV resistance		acc. to EN 50620 resp. VDE 0285-620 acc. to EN ISO 4892-2-2013, method A (change of colour allowed)																																												
Ozone resistance		acc. to EN 50396 resp. VDE 0473-396, method B																																												
Oil Resistant Jacket (UL758&UL1581)		(7d @ 60°C)																																												
Cold bend (-40°Cx4h)		No cracks																																												
Minimum bending radius		Occasional flexing: 12.5 x cable diameter Fixed installation: 6 x cable diameter																																												
General requirements		These cables are conform to the EU-Directive 2014/35/EU (Low Voltage Directive)																																												
2.Design and Construction Data <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 10%;">Item</th> <th style="width: 15%;">Description</th> <th style="width: 75%;">UnitA</th> </tr> </thead> <tbody> <tr> <td rowspan="3">Conductor</td> <td>No. of pair</td> <td>3C (1.5mm²)</td> </tr> <tr> <td>Material</td> <td>Bare copper wire</td> </tr> <tr> <td>Construction</td> <td>48/0.20±0.008 (IEC 60228 Class 5)</td> </tr> <tr> <td rowspan="4">Insulation</td> <td>Material</td> <td>PVC</td> </tr> <tr> <td>Nom. Thickness</td> <td>0.35</td> </tr> <tr> <td>Nom. O.D.:</td> <td>2.35±0.10</td> </tr> <tr> <td>Color</td> <td>1.Brown 2.White 3.Black</td> </tr> <tr> <td>Filler</td> <td>Material</td> <td>Cotton yarn</td> </tr> <tr> <td rowspan="2">Seperator</td> <td>Material</td> <td>Cotton paper</td> </tr> <tr> <td>Overlap</td> <td>≥25%</td> </tr> <tr> <td rowspan="4">Jacket</td> <td>Material</td> <td>TPU</td> </tr> <tr> <td>Nom. Thickness</td> <td>0.70</td> </tr> <tr> <td>Nom. O.D.:</td> <td>6.70±0.20</td> </tr> <tr> <td>Color</td> <td>Black</td> </tr> <tr> <td rowspan="2">Marking</td> <td> CAB1402H POWER CABLE 3X1.5mm² 300/500V RoHS TPU</td> <td></td> </tr> <tr> <td>Color</td> <td>White (Ink printing)</td> </tr> </tbody> </table>			Item	Description	UnitA	Conductor	No. of pair	3C (1.5mm ²)	Material	Bare copper wire	Construction	48/0.20±0.008 (IEC 60228 Class 5)	Insulation	Material	PVC	Nom. Thickness	0.35	Nom. O.D.:	2.35±0.10	Color	1.Brown 2.White 3.Black	Filler	Material	Cotton yarn	Seperator	Material	Cotton paper	Overlap	≥25%	Jacket	Material	TPU	Nom. Thickness	0.70	Nom. O.D.:	6.70±0.20	Color	Black	Marking	CAB1402H POWER CABLE 3X1.5mm ² 300/500V RoHS TPU		Color	White (Ink printing)	4.Cross-section <div style="text-align: center; margin: 20px 0;"> </div>		
Item	Description	UnitA																																												
Conductor	No. of pair	3C (1.5mm ²)																																												
	Material	Bare copper wire																																												
	Construction	48/0.20±0.008 (IEC 60228 Class 5)																																												
Insulation	Material	PVC																																												
	Nom. Thickness	0.35																																												
	Nom. O.D.:	2.35±0.10																																												
	Color	1.Brown 2.White 3.Black																																												
Filler	Material	Cotton yarn																																												
Seperator	Material	Cotton paper																																												
	Overlap	≥25%																																												
Jacket	Material	TPU																																												
	Nom. Thickness	0.70																																												
	Nom. O.D.:	6.70±0.20																																												
	Color	Black																																												
Marking	CAB1402H POWER CABLE 3X1.5mm ² 300/500V RoHS TPU																																													
	Color	White (Ink printing)																																												
5.Remark: 1).Reference standard: UL1581&EN 50525-2-51&EN 50525-2-21; 1).The cable is complied with RoHS standard; 2).The unit of the dimension is mm unless specified in the specification; 3).The cross sections do not represent the actual size for your information;																																														